

September 03, 2014

Chair

Klarissa J. Peña
City of Albuquerque
Councilor, District 3

Vice Chair

Maggie Hart Stebbins
County of Bernalillo
Commissioner, District 3

Richard J. Berry
City of Albuquerque
Mayor

Art De La Cruz
County of Bernalillo
Commissioner, District 2

Rey Garduño
City of Albuquerque
Councilor, District 6

Trudy E. Jones
City of Albuquerque
Councilor, District 8

Debbie O'Malley
County of Bernalillo
Commissioner, District 1

Ex-Officio Member
Pablo R. Rael
Village of Los Ranchos
Board Trustee

Executive Director
Mark S. Sanchez

Website
www.abcwua.org

Gladys Gooden-Jackson
US EPA, Region 6 (6EN)
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733

Via USPS Priority Mail: Signature Confirmation Receipt: 2308 0440 0000 3620 3366

SUBJECT: NPDES Permit #NM0022250 Annual Pretreatment Report 2013 - 2014

Dear Ms. Gooden-Jackson:

Attached is the Annual Pretreatment Report of the Albuquerque Bernalillo County Water Utility Authority for the Pretreatment Year from July 01, 2013, through June 30, 2014, as required in Part II, Section A, of the National Pollutant Discharge Elimination System (NPDES) permit. The report includes the following information:

- 1) Pretreatment Performance Summary
- 2) Significant Industrial Users List
- 3) Significantly Non-Compliant Users By Facility Enforcement Action Taken
- 4) Significant Industrial Users Industry Permits Terminated
- 5) Public Notice for Significant Noncompliance, published in The Albuquerque Journal on August 10, 2014.
- 6) Analyses of Treatment Facility Influent and Effluent
- 7) System Manholes Priority Pollutant Scan
- 8) Sludge/Biosolids Priority Pollutant Scan
- 9) Summary of Minimum Quantification Levels

No interference, pass through, upset or Publically Owned Treatment Works (POTW) violations are known or suspected to have been caused by industrial contributors during the 12 month period from July 01, 2013 through June 30, 2014.

Sincerely,



Charles S. Leder, P.E., Plant Operations Division Manager

cc: Bruce Yurdin, Program Manager, Surface Water Quality Bureau, NMED
John M. Stomp, III, P.E., Chief Operating Officer, ABCWUA
Ramona Montoya, Environment Division Manager, Pueblo of Isleta

PRETREATMENT PERFORMANCE SUMMARY (PPS)

I. General Information

Control Authority Name	ABCWUA	
Address	4201 2nd Street SW	
City	Albuquerque	State/Zip NM/87105
Contact Person	Charles Leder	
Contact Phone	(505) 873-7072	
NPDES Permit Nos.	NM0022250	
Reporting Period	July 2013	June 2014

Total Number of Categorical IUs	41
Total Number of Significant Noncategorical IUs	32

II. Significant Industrial User Compliance

	Categorical	Non-Categorical
1) No. of SIUs Submitting BMRs/Total No. Required	0/0	0/0
2) No. of SIUs Submitting 90-Day Compliance Reports/Total No. Required	0/0	0/0
3) No. of SIUs Submitting Semiannual Reports/Total No. of SIUs *	38/38	32/32
4) No. of SIUs Submitting Meeting Compliance Schedule/Total No. Required	3/3	3/3
5) No. of SIUs in Significant Noncompliance/Total No. of SIUs	3/41	1/32
6) Rate of Significant Noncompliance for all SIUs (*3 New SIU-No SA Required)	5% (or 4 out of 73)	

III. Compliance Monitoring Program

1) No. of Control Document Issued/Total No. Required	6/6	1/1
2) No. of Nonsampling Inspections Conducted	50	34
3) No. of Sampling Visits Conducted	297	641
4) No. of Facilities Inspected (nonsampling)	41	32
5) No. of Facilities Sampled (* 4 CIUs were Zero Discharge 2 CIUs had zero process water)	36	31

IV. Enforcement Actions

SIGNIFICANT INDUSTRIAL USERS

1) No. of Compliance Schedules Issued/No. of Schedules Required	3/3	2/2
2) No. of Notices of Violations Issued to SIUs	13	22
3) No. of Administrative Orders Issued to SIUs	0	1
4) No. of Civil Suits Filed	0	0
5) No. of Criminal Suits Filed	0	0
6) No. of Significant Violators (attach newspaper publication)	3	1
7) Amount of Penalties Collected (total dollars/IUs assessed)	\$0.00	\$2,000.00
8) Other Actions (sewer bans, etc.)..Reimbursement costs	\$0.00	\$9,968.54

The following certification must be signed in order for this form to be considered complete:
 I certify that the information contained herein is complete and accurate to the best of my knowledge.

Charles A. Leder MANAGER - PLANT OPERATIONS DIVISION SEP 04 2014
 Authorized Representative Date

**PRETREATMENT PROGRAM STATUS REPORT UPDATED
SIGNIFICANT INDUSTRIAL USERS LIST**

PERMITTEE: ABCWUA
REPORTING PERIOD: 07/01/2013 - 06/30/2014
PERMIT NUMBER: NM0022250

INDUSTRIAL USER	SIC CODE	CATEGORICAL DETERMINATION	Y/N	CONTROL DOCUMENT LAST ACTION		NEW USER Y/N	TIMES INSPECTED	TIMES SAMPLED (days sampled)	90-DAY COMPLIANCE BMR	REPORTS			EFFLUENT LIMITS	
				TYPE	DATE					SEMI ANNUAL	SELF MONITORING	OTHER REPORTING		
2215A ABQ Manufacturing, Inc.	3471	433	Y	RENEWED	04-23-10	N	1	7(ZD)	-	-	C	N/A	-	SNC
2255A Advanced Galvanics	3471	433	Y	ISSUED	01-01-14	N	1	2	-	-	C	N/A	-	N
2046A Albuquerque Publishing Company	2711	N/A	Y	RENEWED	09-21-11	N	1	19	-	-	C	N/A	-	C
2047A Ameripride Linen and Apparel Services	7211	N/A	Y	RENEWED	05-04-10	N	2	65	-	-	C	N/A	-	N
2091A Brothers Plating Company, Inc.	3479	433	Y	RENEWED	04-26-10	N	1	7	-	-	C	N/A	-	N
2251A Cabot Security Materials Inc.	3399	471	Y	ISSUED	03-30-12	N	1	5	-	-	C	N/A	-	N
2227A Cabot Security Materials Inc.	8731	471	Y	RENEWED	07-16-10	N	1	6	-	-	C	N/A	-	N
2196A Chem-Tech, Inc. dba/Darco Products, Inc.	3471	433	Y	RENEWED	11-04-10	N	1	0(ZD)	-	-	C	N/A	-	C
2238A CINT (Center For Integrated Nano Technologies)	8733	433, 469	Y	RENEWED	05-25-11	N	1	6	-	-	C	N/A	-	C
2246A Cottonwood Mall	6512	N/A	Y	ISSUED	06-15-11	N	1	17	-	-	C	N/A	-	C
2034A CTS Electronic Components, Inc.	3299	469	Y	RENEWED	01-21-11	N	1	16	-	-	C	N/A	-	C

**PRETREATMENT PROGRAM STATUS REPORT UPDATED
SIGNIFICANT INDUSTRIAL USERS LIST**

PERMITTEE: ABCWUA

REPORTING PERIOD: 07/01/2013 - 06/30/2014

PERMIT NUMBER: NM0022250

INDUSTRIAL USER	SIC CODE	CATEGORICAL DETERMINATION	Y/N	CONTROL DOCUMENT LAST ACTION		NEW USER Y/N	TIMES INSPECTED	TIMES SAMPLED (days sampled)	90-DAY COMPLIANCE	BMR	REPORTS			EFFLUENT LIMITS
				TYPE	DATE						SEMI ANNUAL	SELF MONITORING	OTHER REPORTING	
2006A Dean Dairy Holdings, LLC	2026	405	Y	RENEWED	07-14-10	N	1	16	-	-	C	N/A	-	C
2207A Delta Uniform and Linen, Inc.	7211	N/A	Y	RENEWED	04-02-12	N	1	20	-	-	C	N/A	-	C
2069K Department of Energy and Sandia National Laboratories	8731	N/A	Y	RENEWED	05-25-10	N	1	4	-	-	C	N/A	-	N
2069A Department of Energy and Sandia National Laboratories	8731	N/A	Y	ISSUED	02-28-13	N	1	4	-	-	C	N/A	-	N
2069F Department of Energy and Sandia National Laboratories	3471	N/A	Y	RENEWED	03-24-14	N	1	6	-	-	C	N/A	-	N
2069I Department of Energy and Sandia National Laboratories	8733	N/A	Y	RENEWED	06-15-10	N	1	13	-	-	C	N/A	-	N
2069G Department of Energy and Sandia National Laboratories	3674	433, 469	Y	RENEWED	05-05-10	N	1	6	-	-	C	N/A	-	N
2039A DGW, Inc. dba/G&S Jewelry Mfg.	3479	413	Y	RENEWED	08-24-10	N	1	19	-	-	C	N/A	-	N
2235A Eclipse Aerospace	2844	433	Y	RENEWED	06-21-11	N	2	1	-	-	C	N/A	-	C
2206A Ecotex-Healthcare Laundry Services, LLC	7211	N/A	Y	RENEWED	09-23-10	N	1	16	-	-	C	N/A	-	C
2002A El Encanto, Inc.	2099	N/A	Y	RENEWED	07-10-12	N	1	16	-	-	C	N/A	-	C

**PRETREATMENT PROGRAM STATUS REPORT UPDATED
SIGNIFICANT INDUSTRIAL USERS LIST**

PERMITTEE: ABCWUA
REPORTING PERIOD: 07/01/2013 - 06/30/2014
PERMIT NUMBER: NM0022250

	INDUSTRIAL USER	SIC CODE	CATEGORICAL DETERMINATION	Y/N	CONTROL DOCUMENT LAST ACTION		NEW USER Y/N	TIMES INSPECTED	TIMES SAMPLED (days sampled)	90-DAY COMPLIANCE	BMR	REPORTS			EFFLUENT LIMITS
					TYPE	DATE						SEMI ANNUAL	SELF MONITORING	OTHER REPORTING	
2209A	Emcore Corporation dba/Emcore West	3679	469	Y	RENEWED	06-15-11	N	1	8	-	-	C	N/A	-	C
2018A	Ethicon Endo-Surgery, Inc.	3841	N/A	Y	RENEWED	07-28-10	N	1	14	-	-	C	N/A	-	C
2253A	EXPO New Mexico	7999	412.15	Y	ISSUED	03-14-13	N	1	17	-	-	C	N/A	-	C
2232A	Formulab . . .Naturally!	2844	417	Y	RENEWED	02-02-11	N	2	15	-	-	C	N/A	-	C
2051A	G&K Services, Inc.	7218	N/A	Y	RENEWED	05-17-10	N	1	16	-	-	C	N/A	-	C
2252A	G.T. Specialties	3471	433	Y	ISSUED	09-20-12	N	1	8	-	-	C	N/A	-	C
2181A	General Mills Operations, Inc.	2043	406	Y	RENEWED	10-04-12	N	1	16	-	-	C	N/A	-	C
2058A	Gibson Medical Center, LLC	8011	N/A	Y	RENEWED	06-30-10	N	1	11	-	-	C	N/A	-	N
2249A	Gruma Corporation	2099	N/A	Y	ISSUED	09-21-11	N	1	21	-	-	C	N/A	-	C
2223A	HT Micro Analytical, Inc.	3679	433	Y	RENEWED	06-01-14	N	2	3	-	-	C	N/A	-	N
2214A	Ink Spot Towel Service, Inc.	7218	N/A	Y	RENEWED	05-26-10	N	1	10	-	-	C	N/A	-	C

**PRETREATMENT PROGRAM STATUS REPORT UPDATED
SIGNIFICANT INDUSTRIAL USERS LIST**

PERMITTEE: ABCWUA
 REPORTING PERIOD: 07/01/2013 - 06/30/2014
 PERMIT NUMBER: NM0022250

INDUSTRIAL USER	SIC CODE	CATEGORICAL DETERMINATION	Y/N	CONTROL DOCUMENT		NEW USER Y/N	TIMES INSPECTED	TIMES SAMPLED (days sampled)	90-DAY COMPLIANCE	BMR	REPORTS			EFFLUENT LIMITS
				LAST ACTION TYPE	DATE						SEMI ANNUAL	SELF MONITORING	OTHER REPORTING	
2021A Intel Corporation	3674	469	Y	RENEWED	02-16-10	N	1	18	-	-	C	N/A	-	C
2037A Jewelry by Coleman	3369	433	Y	TERMINATED	04-23-14	N	2	0(ZD)	-	-	C	N/A	-	C
2022A Kaehr Corporation	3471	413	Y	RENEWED	05-04-10	N	1	17	-	-	C	N/A	-	N
2057A Kaseman Presbyterian Hospital	8062	N/A	Y	RENEWED	05-01-14	N	1	23	-	-	C	N/A	-	C
2068A Kirtland Air Force Base	9711	N/A	Y	RENEWED	05-14-10	N	1	8	-	-	C	N/A	-	C
2060A Lovelace Medical Center	8062	N/A	Y	RENEWED	12-07-11	N	1	12	-	-	C	N/A	-	C
2178A Lovelace Respiratory Research Institute	8733	N/A	Y	RENEWED	08-15-12	N	1	4	-	-	C	N/A	-	N
2089A Lovelace Westside Hospital	8062	N/A	Y	RENEWED	03-07-12	N	1	4	-	-	C	N/A	-	C
2061A Lovelace Women's Hospital	8062	N/A	Y	RENEWED	05-04-10	N	1	29	-	-	C	N/A	-	N
2248A Materion Advanced Materials Technologies & Services	3341	421.126, 421.266	Y	ISSUED	06-24-11	N	1	6	-	-	C	N/A	-	SNC
2192A Materion Advanced Materials Technologies & Services	3399	421.266, 433	Y	TERMINATED	01-17-14	N	1	7	-	-	C	N/A	-	N

**PRETREATMENT PROGRAM STATUS REPORT UPDATED
SIGNIFICANT INDUSTRIAL USERS LIST**

PERMITTEE: ABCWUA
 REPORTING PERIOD: 07/01/2013 - 06/30/2014
 PERMIT NUMBER: NM0022250

INDUSTRIAL USER	SIC CODE	CATEGORICAL DETERMINATION	Y/N	CONTROL DOCUMENT LAST ACTION		NEW USER Y/N	TIMES INSPECTED	TIMES SAMPLED (days sampled)	90-DAY COMPLIANCE	BMR	REPORTS			EFFLUENT LIMITS
				TYPE	DATE						SEMI ANNUAL	SELF MONITORING	OTHER REPORTING	
2257A Materion Advanced Technologies	3341	471	Y	ISSUED	04-01-14	N	2	1(ZD)	-	-	C	N/A	-	C
2013A Materion Advanced Technologies	3341	421, 471	Y	ISSUED	04-17-14	N	2	6	-	-	C	N/A	-	N
2221A Metal Finishing Specialty	3471	433	Y	RENEWED	07-09-12	N	2	0(ZD)	-	-	C	N/A	-	C
2087A Mission Linen & Uniform Service	7219	N/A	Y	RENEWED	02-14-12	N	1	18	-	-	C	N/A	-	C
2244A MSR-FSR LLC	7218	N/A	Y	ISSUED	01-01-11	N	1	2	-	-	C	N/A	-	C
2071A National Research Laboratories, Inc.	3672	433	Y	RENEWED	01-20-12	N	1	5	-	-	C	N/A	-	C
2242A New Mexico Scientific Laboratories	8734	N/A	Y	RENEWED	07-10-10	N	1	16	-	-	C	N/A	-	C
2064A New Mexico VA Health Care System	8062	N/A	Y	RENEWED	07-21-10	N	1	19	-	-	C	N/A	-	C
2225A NK Asphalt Partners	2911	443	Y	RENEWED	10-18-11	N	1	4(ZD)	-	-	C	N/A	-	C
2241A Optimum Finish, Inc.	3471	433	Y	ISSUED	06-22-10	N	2	2	-	-	C	N/A	-	C
2055B OSO Biopharmaceuticals Mfg.	8731	439	Y	RENEWED	05-25-10	N	1	4(ZD)	-	-	C	N/A	-	C

**PRETREATMENT PROGRAM STATUS REPORT UPDATED
SIGNIFICANT INDUSTRIAL USERS LIST**

PERMITTEE: ABCWUA
REPORTING PERIOD: 07/01/2013 - 06/30/2014
PERMIT NUMBER: NM0022250

INDUSTRIAL USER	SIC CODE	CATEGORICAL DETERMINATION	Y/N	CONTROL DOCUMENT LAST ACTION		NEW USER Y/N	TIMES INSPECTED	TIMES SAMPLED (days sampled)	90-DAY COMPLIANCE BMR	REPORTS			EFFLUENT LIMITS	
				TYPE	DATE					SEMI ANNUAL	SELF MONITORING	OTHER REPORTING		
2055A OSO Biopharmaceuticals Mfg.	2834	439	Y	RENEWED	05-25-10	N	1	4	-	-	C	N/A	-	C
2059A Presbyterian Healthcare Services	8062	N/A	Y	RENEWED	09-23-11	N	1	18	-	-	C	N/A	-	C
2190A Prudential Overall Supply	7218	N/A	Y	RENEWED	04-28-10	N	1	19	-	-	C	N/A	-	C
2250A Raytheon Company		433	Y	ISSUED	11-03-11	N	1	0(ZD)	-	-	C	N/A	-	C
2041B Red Sky Corporation	3471	433	Y	RENEWED	04-26-10	N	1	4	-	-	C	N/A	-	N
2222A Stericycle, Inc.	4953	N/A	Y	RENEWED	03-31-13	N	1	8	-	-	C	N/A	-	C
2195A SUMCO Phoenix Corporation	3674	469	Y	RENEWED	04-30-10	N	1	8	-	-	C	N/A	-	C
2254A Sumitomo Electric Device Innovations USA, Inc.	3674	469	Y	ISSUED	11-27-13	N	1	11	-	-	C	N/A	-	N
2044A Sunwest Silver Co., Inc. dba/Waldeck Jewelers	3471	N/A	Y	RENEWED	12-05-11	N	1	0**	-	-	C	N/A	-	C
2256A TCS Industries	3444	433	Y	ISSUED	03-07-14	N	2	2(ZD)	-	-	C	N/A	-	N
2026A The Circuit Shop, Inc.	3672	413	Y	RENEWED	06-14-10	N	1	8	-	-	C	N/A	-	N

**PRETREATMENT PROGRAM STATUS REPORT UPDATED
SIGNIFICANT INDUSTRIAL USERS LIST**

PERMITTEE: ABCWUA
 REPORTING PERIOD: 07/01/2013 - 06/30/2014
 PERMIT NUMBER: NM0022250

INDUSTRIAL USER	SIC CODE	CATEGORICAL DETERMINATION	Y/N	CONTROL DOCUMENT LAST ACTION		NEW USER Y/N	TIMES INSPECTED	TIMES SAMPLED (days sampled)	90-DAY COMPLIANCE BMR	REPORTS			EFFLUENT LIMITS	
				TYPE	DATE					SEMI ANNUAL	SELF MONITORING	OTHER REPORTING		
2237A The Paint Shop	3471	433	Y	RENEWED	01-24-11	N	1	16	-	-	C	N/A	-	C
2043A Theta Plata, Inc.	3471	433	Y	RENEWED	12-16-11	N	1	8	-	-	C	N/A	-	N
2028A Thomas & Betts Corporation dba/Elastimold	3069	428	Y	RENEWED	05-14-10	N	1	2	-	-	C	N/A	-	SNC
2230A TPL, Inc.	8731	469	Y	RENEWED	08-29-12	N	1	0**	-	-	C	N/A	-	C
2186A Unifirst Corporation	7218	N/A	Y	RENEWED	04-29-10	N	2	60	-	-	C	N/A	-	SNC
2062A University of New Mexico Health Sciences Center/Hospital	8062	N/A	Y	ISSUED	02-21-12	N	1	20	-	-	C	N/A	-	C
2076A Wagner Equipment Co.	5082	N/A	Y	RENEWED	05-03-10	N	1	19	-	-	C	N/A	-	C

NOTES: ** = Not required during reporting period
 0* = This facility shut down early in the reporting period with no process water sampled during the year
 0** = Very low production, no process water discharge during the year
 0 (ZD) = No samples were collected because the Permittee had Zero Discharge for Process water
 C = Compliant
 N = Noncompliant
 SELF MONITORING = The Control Authority performs all compliance monitoring. As a result, Self Monitoring is Not Applicable (N/A)
 SNC = Significant Non-Compliant
 TIMES SAMPLED = The number of days a permittee was sampled. The actual count of samples taken for each permit may be greater than indicated multiple sample points and multiple grabs

SIGNIFICANTLY NONCOMPLIANT USERS BY FACILITY ENFORCEMENT ACTION TAKEN

PERMITTEE: ABCWUA
 REPORTING PERIOD: 07/01/2013 - 06/30/2014
 PERMIT NUMBER: NM0022250

INDUSTRIAL USER	NATURE OF VIOLATION		NUMBER OF ACTIONS TAKEN					OTHER ACTIONS TAKEN	PENALTIES COLLECTED	COMPLIANCE SCHEDULE **		CURRENT STATUS ***	COMMENTS
	REPORTS	LIMITS	NOV*	AO	CIVIL	CRIMINAL	DATE ISSUED (IU Compliance Sched. Date)			DATE DUE (IU proposed Return To Compliance Date)			
2215A	ABQ Manufacturing, Inc.	ZN	4	0	0	0		-	7/1/2013 ZN	8/21/2013 ZN	C (ZN)		
2248A	Materion Advanced Materials Technologies & Services	MO	8	0	0	0		-	6/25/2014 F 6/25/2014 MO	7/31/2014 F 7/31/2014 MO	N (F) N (MO)		
2028A	Thomas & Betts Corporation dba/Elastimold	ZN	1	0	0	0		-	<none> ZN	<none> ZN	N (ZN)		
2186A	Unifirst Corporation	TPH	10	1	0	0		\$1,600.00	6/19/2014 TPH	8/18/2014 TPH	N (TPH)		

NOTES: * NOVs include both formal written notices and documented phone notices for violations that occurred during the reporting year (07/01/2013 - 06/30/2014)
 ** Compliance schedule dates (Issued Due) are indicated for violations occurring in the Reporting Year. Some Compliance Dates are post 06/30/2014
 *** C=Compliant, N=Non Compliant
 NOV = Notice of Violation
 AO = Administrative Order

CTS - Compliance Tracking System

**SIGNIFICANT INDUSTRIAL USERS
INDUSTRY PERMITS TERMINATED**

PERMITTEE: ABCWUA
REPORTING PERIOD: 07/01/2013 - 06/30/2014
PERMIT NUMBER: NM0022250

Permit Number	SIU Last reporting period	SIU this reporting period	Company Name	Reason for Permit Termination	Termination Date
2037A	Yes	Yes	Jewelry by Coleman	Permit has been Inactivated	4/23/2014
2192A	Yes	Yes	Materion Advanced Materials Technologies & Services	Permit has been Inactivated	1/17/2014



Water Utility Authority

This notice is published in accordance with Section 3-D-1 of the Albuquerque Bernalillo County Water Utility Authority Sewer Use and Wastewater Control Ordinance, Federal Regulation 40 CFR 403.8 (f) (2) (vi), and with the Water Authority National Pollutant Discharge Elimination System Permit (RW0022250), as issued by the United States Environmental Protection Agency. Pursuant to the above, the Water Authority hereby provides public notification of industrial users of the Water Authority sanitary sewer system which, during the period of July 1, 2013, through June 30, 2014, were in significant noncompliance with one or more of the applicable pretreatment standards or requirements.

The following users are in the process of returning to compliance with applicable pretreatment standards or requirements.

Mesacon Advanced Materials
Technologies & Services
United Corporation
Thomas & Betts Corporation

The following user successfully returned to compliance with applicable pretreatment standards or requirements.

ABQ Manufacturing, Inc.

Additional information regarding noncompliance and enforcement of the Sewer Use and Wastewater Control Ordinance may be obtained by contacting Mark Kelly, Industrial Pretreatment Engineer, at (505) 873-7047 during normal business hours (8 AM to 5 PM Monday through Friday) or by emailing pretreatment@abcwua.org. TTY Users please call NM Relay at 1-800-859-8337.
Journal: August 10, 2014

Albuquerque Bernalillo County Water Utility Authority Southside Water Reclamation Plant

Influent and Effluent Averages
Reporting Year: July 01, 2013 - June 30, 2014
NPDES Permit Number: NM0022250

POLLUTANT Metals, Cyanide and Phenols	MAHL (if applicable in Ug/l) (1)	Averages of Influent Values (2) 2013 - 2014	Monthly Average Effluent Limit	Daily Average Effluent Limit	Averages of Effluent Values (3) 2013 - 2014	MQL (4)	Units
Average Daily Flow: 50 MGD							
ALUMINUM, TOTAL	N/A	1364.4			<36.7		2.5 ug/L
ANTIMONY, TOTAL	N/A	<1.4			<0.9		60 ug/L
ARSENIC, TOTAL	17	<9.9			<3.9		0.5 ug/L
BERYLLIUM, TOTAL	N/A	<0.3			<0.4		0.5 ug/L
BORON, DISSOLVED	N/A						- ug/L
BORON, TOTAL	N/A	381.4			<304.1		100 ug/L
CADMIUM, TOTAL	7.3	0.5			<0.1		1 ug/L
CHROMIUM, TOTAL	806	<36.6			<25.3		10 ug/L
COPPER, TOTAL	255	150.8			<3.6		0.5 ug/L
CYANIDE, TOTAL, DISTILLED	49.7	<10.0			<10.0		10 ug/L
FLUORIDE/ELECTRODE	7900	0.9			0.9		- mg/L
LEAD, TOTAL	49.7	7.9			<0.4		0.5 ug/L
MERCURY, TOTAL	0.9	0.1	0.008	0.012	0.0	0.0005	ug/L
MOLYBDENUM, DISSOLVED	N/A						10 ug/L
MOLYBDENUM, TOTAL	74	8.5			<5.7		10 ug/L
NICKEL, TOTAL	47.3	8.9			<2.8		0.5 ug/L
PHENOLIC	N/A	<75.5			<59.4		- ug/L
SELENIUM, TOTAL	7.4	<1.9			<1.8		5 ug/L
SILVER, TOTAL	174	4.1			<0.6		0.5 ug/L
SULFIDE	N/A	3381.3			<500.0		- ug/L
THALLIUM, TOTAL	N/A	<0.9			<1.0		0.5 ug/L
ZINC, TOTAL	519	457.8			<154.4		20 ug/L

(1) Maximum Allowable Headworks Loading (MAHL) Limitation in ug/L values determined from EPA approved Local Limits Technical Analysis using the most limiting condition for mass with 55 MGD as a basis.

(2) Influent was monitored monthly with annual averages shown.

(3) Results are annual averages of monthly or weekly monitoring.

(4) MQLs from the October 1, 2012 Permit.

Notes:

"<" appearing next to an averaged result indicates that one or more results used in the average was below detectable limit.
Influent & effluent samples were collected 12 hours apart considering the flow detention time through the plant.
Monthly Average Effluent Limits are based on the Water Authority's NPDES permit, effective date October 1, 2012.

APPENDIX A of PART II

The following Minimum Quantification Levels (MQL's) are to be used for reporting pollutant data for NPDES permit applications and/or compliance reporting.

POLLUTANTS	MQL µg/l	POLLUTANTS	MQL µg/l
METALS, RADIOACTIVITY, CYANIDE and CHLORINE			
Aluminum	2.5	Molybdenum	10
Antimony	60	Nickel	0.5
Arsenic	0.5	Selenium	5
Barium	100	Silver	0.5
Beryllium	0.5	Thallium	0.5
Boron	100	Uranium	0.1
Cadmium	1	Vanadium	50
Chromium	10	Zinc	20
Cobalt	50	Cyanide	10
Copper	0.5	Cyanide, weak acid dissociable	10
Lead	0.5	Total Residual Chlorine	33
Mercury *1	0.0005 0.005		
DIOXIN			
2,3,7,8-TCDD	0.00001		
VOLATILE COMPOUNDS			
Acrolein	50	1,3-Dichloropropylene	10
Acrylonitrile	20	Ethylbenzene	10
Benzene	10	Methyl Bromide	50
Bromoform	10	Methylene Chloride	20
Carbon Tetrachloride	2	1,1,2,2-Tetrachloroethane	10
Chlorobenzene	10	Tetrachloroethylene	10
Chlorodibromomethane	10	Toluene	10
Chloroform	50	1,2-trans-Dichloroethylene	10
Dichlorobromomethane	10	1,1,2-Trichloroethane	10
1,2-Dichloroethane	10	Trichloroethylene	10
1,1-Dichloroethylene	10	Vinyl Chloride	10
1,2-Dichloropropane	10		
ACID COMPOUNDS			
2-Chlorophenol	10	2,4-Dinitrophenol	50
2,4-Dichlorophenol	10	Pentachlorophenol	5
2,4-Dimethylphenol	10	Phenol	10
4,6-Dinitro-o-Cresol	50	2,4,6-Trichlorophenol	10

Summary of Minimum Quantification Levels

The list of minimum quantification levels (MQLs) required by the NPDES permit effective October 2012 – present is attached. During the pretreatment year, all effluent monitoring was conducted according to the attached MQLs except for the analytes Aluminum, Beryllium, Chromium, Copper, Lead, Nickel, Silver, and Thallium. Table 1 shows a comparison of the required MQL and the MQL used.

Table 1

Analyte	MQL Required (ug/L)	MQL Used (ug/L)
Aluminum	2.5	60
Beryllium	0.5	2
Chromium	10	30
Copper	0.5	4 & 1
Lead	0.5	1
Nickel	0.5	4 & 1
Silver	0.5	3
Thallium	0.5	3.8 & 1

For Aluminum, Beryllium, Chromium, Lead and Silver, one (1) of 12 results did not meet the required MQL. For Copper, and Thallium, two (2) of 12 results did not meet the required MQL. For Nickel, three (3) of 12 results did not meet the required MQL. These results occurred between July 2013 and September 2013. Monitoring meeting the MQL was done for each analyte at least once per two month period as required by the permit.

Albuquerque Bernalillo County Water Utility Authority Southside Water Reclamation Plant

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014

Total Petroleum Hydrocarbons and Oil and Grease

NPDES Permit Number: NM0022250

Method: EPA 1664A

LOCATION	POLLUTANT	DATE	RESULT	UNIT
Influent	O&G	7/15/2013	15	mg/L
Influent	O&G	7/15/2013	16	mg/L
Influent	O&G	7/15/2013	23.1	mg/L
Influent	O&G	7/15/2013	12	mg/L
Effluent	O&G	7/15/2013	<5.4	mg/L
Effluent	O&G	7/15/2013	<5.2	mg/L
Effluent	O&G	7/16/2013	<5.0	mg/L
Effluent	O&G	7/16/2013	<5.4	mg/L
Influent	O&G	8/19/2013	9.6	mg/L
Influent	O&G	9/16/2013	12	mg/L
Influent	O&G	10/21/2013	18	mg/L
Influent	O&G	11/18/2013	13	mg/L
Influent	O&G	12/16/2013	7.1	mg/L
Influent	O&G	1/13/2014	15	mg/L
Influent	O&G	1/14/2014	666	mg/L
Influent	O&G	1/14/2014	30	mg/L
Influent	O&G	1/14/2014	17	mg/L
Effluent	O&G	1/14/2014	<5.2	mg/L
Effluent	O&G	1/14/2014	<5.3	mg/L
Effluent	O&G	1/14/2014	<5.3	mg/L
Effluent	O&G	1/15/2014	<5.2	mg/L
Influent	O&G	2/10/2014	57	mg/L
Influent	O&G	4/21/2014	17	mg/L
Influent	O&G	5/19/2014	33	mg/L
Influent	O&G	6/9/2014	29	mg/L
LOCATION	POLLUTANT	DATE	RESULT	UNIT
Influent	TPH	7/15/2013	<5.5	mg/L
Influent	TPH	7/15/2013	9.9	mg/L
Influent	TPH	7/15/2013	9.0	mg/L
Influent	TPH	7/15/2013	<5.3	mg/L
Effluent	TPH	7/15/2013	<5.4	mg/L
Effluent	TPH	7/15/2013	<5.2	mg/L
Effluent	TPH	7/16/2013	<5.4	mg/L
Effluent	TPH	7/16/2013	<5.0	mg/L
Influent	TPH	8/19/2013	<5.5	mg/L
Influent	TPH	9/16/2013	7.0	mg/L
Influent	TPH	10/21/2013	<5.5	mg/L
Influent	TPH	11/18/2013	<5.8	mg/L
Influent	TPH	12/16/2013	<5.9	mg/L
Influent	TPH	1/13/2014	<5.7	mg/L
Influent	TPH	1/14/2014	<5.3	mg/L
Influent	TPH	1/14/2014	<5.2	mg/L

Twelve (12) hour flow-through observed by staggering influent effluent sampling.
All samples were collected as grabs.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014

Total Petroleum Hydrocarbons and Oil and Grease

NPDES Permit Number: NM0022250

Method: EPA 1664A

LOCATION	POLLUTANT	DATE	RESULT	UNIT
Influent	TPH	1/14/2014	64	mg/L
Effluent	TPH	1/14/2014	<5.2	mg/L
Effluent	TPH	1/14/2014	<5.3	mg/L
Effluent	TPH	1/14/2014	<5.3	mg/L
Effluent	TPH	1/15/2014	<5.2	mg/L
Influent	TPH	2/10/2014	41	mg/L
Influent	TPH	4/21/2014	<5.7	mg/L
Influent	TPH	5/19/2014	<6.0	mg/L
Influent	TPH	6/9/2014	<5.5	mg/L

Twelve (12) hour flow-through observed by staggering influent effluent sampling.
All samples were collected as grabs.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
11/4/2013 6:00:00 AM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	1.6	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	1.7	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	1,2-Dichloroethene	ND
			1,1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	1.5	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethane	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
11/4/2013 12:00:00 PM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	2	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	1.9	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	1,2-Dichloroethene	ND
			1,1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethane	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(3) All results in µg/L

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
11/4/2013 6:00:00 PM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	2	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	3.1	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethane	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	1.5	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethane	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
11/4/2013 11:59:00 PM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	2	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	2.5	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethane	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	1.3	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethane	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(3) All results in µg/L

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/13/2014 7:30:00 PM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	2.5	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	2.9	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/14/2014 1:30:00 AM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

(3) All results in µg/L

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/14/2014 7:30:00 AM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromofom	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethane	ND
			1,1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/14/2014 1:30:00 PM	EPA 624	Influent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromofom	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethane	ND
			1,1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethane	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

(3) All results in µg/L

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
			1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
11/4/2013 6:00:00 PM	EPA 624	Effluent	1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
			1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
11/4/2013 11:59:00 PM	EPA 624	Effluent	1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(3) All results in µg/L

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
11/5/2013 6:00:00 AM	EPA 624	Effluent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
11/5/2013 12:00:00 PM	EPA 624	Effluent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

(3) All results in µg/L

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/14/2014 7:30:00 AM	EPA 624	Effluent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/14/2014 1:30:00 PM	EPA 624	Effluent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethene	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(3) All results in µg/L

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/14/2014 7:30:00 PM	EPA 624	Effluent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethane	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC VOLATILE RESULTS							
1/15/2014 1:30:00 AM	EPA 624	Effluent	1,1,1-Trichloroethane	ND	1,1,2,2-Tetrachloroethane	ND	1,1,2-Trichloroethane	ND	1,1-Dichloroethane	ND
			1,1-Dichloroethane	ND	1,2-Dichloroethane	ND	1,2-Dichloropropane	ND	1,3-Dichlorobenzene	ND
			1,4-Dichlorobenzene	ND	2-Chloroethyl vinyl ether	ND	Acrolein	ND	Acrylonitrile	ND
			Benzene	ND	Bromochloromethane	ND	Bromodichloromethane	ND	Bromoform	ND
			Bromomethane	ND	Carbon Tetrachloride	ND	Chlorobenzene	ND	Chlorodibromomethane	ND
			Chloroethane	ND	Chloroform	ND	Chloromethane	ND	cis-1,3-Dichloropropene	ND
			Dibromochloromethane	ND	Ethylbenzene	ND	Methylene Chloride	ND	t-1,2-Dichloroethene	ND
			t-1,3-Dichloropropene	ND	Tetrachloroethene	ND	Toluene	ND	trans-1,2-Dichloroethene	ND
			trans-1,3-Dichloropropene	ND	Trichloroethene	ND	Trichlorofluoromethane	ND	Vinyl Chloride	ND
			Xylenes	ND						

(1) All samples were grab samples @ 6 hour intervals.

(3) All results in µg/L

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014

Priority Pollutant Organic Semi-volatiles

NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC SEMI-VOLATILE RESULTS																																																																																																	
7/16/2013 6:00:00 AM	EPA 625	Influent	1,2,4-Trichlorobenzene	ND	1,2-Dichlorobenzene	ND	1,2-Diphenylhydrazine	ND	1,4-Dichlorobenzene (625)	ND	2,4,6-Trichlorophenol	ND	2,4-Dichlorophenol	ND	2,4-Dimethylphenol	ND	2,4-Dinitrophenol	ND	2,4-Dinitrotoluene	ND	2,6-Dinitrotoluene	ND	2-Chloronaphthalene	ND	2-Chlorophenol	ND	2-Nitrophenol	ND	3,3'-Dichlorobenzidine	ND	4,6-dinitro-2-methylphenol	ND	4-Chloro-3-methylphenol	ND	4-Chlorophenyl-phenylether	ND	4-Nitrophenol	ND	Acenaphthene	ND	Acenaphthylene	ND	Anthracene	ND	Benzidine	ND	Benzo (a) Anthracene	ND	Benzo (a) pyrene	ND	bis (2-Chloroethoxy) methane	ND	bis (2-Chloroethyl) ether	ND	bis (2-Chloroisopropyl) ether	ND	bis (2-Ethylhexyl) phthalate	14.4	Butylbenzylphthalate	ND	Chrysene	ND	Diethylphthalate	9.2	Dimethylphthalate	ND	Di-n-butylphthalate	ND	Di-n-octylphthalate	ND	Fluorene	ND	Fluoroanthene	ND	Hexachlorobenzene	ND	Hexachlorobutadiene	ND	Hexachlorocyclopentadiene	ND	Hexachloroethane	ND	Isophorone	ND	Naphthalene	ND	Nitrobenzene	ND	N-Nitroso-di-n-propylamine	ND	N-Nitrosodiphenylamine	ND	Pentachlorophenol	ND	Phenanthrene	ND	Phenols	33	Pyrene	ND

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC SEMI-VOLATILE RESULTS																																																																																																	
1/15/2014 7:15:00 AM	EPA 625	Influent	1,2,4-Trichlorobenzene	ND	1,2-Dichlorobenzene	ND	1,2-Diphenylhydrazine	ND	1,4-Dichlorobenzene (625)	ND	2,4,6-Trichlorophenol	ND	2,4-Dichlorophenol	ND	2,4-Dimethylphenol	ND	2,4-Dinitrophenol	ND	2,4-Dinitrotoluene	ND	2,6-Dinitrotoluene	ND	2-Chloronaphthalene	ND	2-Chlorophenol	ND	2-Nitrophenol	ND	3,3'-Dichlorobenzidine	ND	4,6-dinitro-2-methylphenol	ND	4-Chloro-3-methylphenol	ND	4-Chlorophenyl-phenylether	ND	4-Nitrophenol	ND	Acenaphthene	ND	Acenaphthylene	ND	Anthracene	ND	Benzidine	ND	Benzo (a) Anthracene	ND	Benzo (a) pyrene	ND	bis (2-Chloroethoxy) methane	ND	bis (2-Chloroethyl) ether	ND	bis (2-Chloroisopropyl) ether	ND	bis (2-Ethylhexyl) phthalate	12.4	Butylbenzylphthalate	ND	Chrysene	ND	Diethylphthalate	ND	Dimethylphthalate	ND	Di-n-butylphthalate	ND	Di-n-octylphthalate	ND	Fluorene	ND	Fluoroanthene	ND	Hexachlorobenzene	ND	Hexachlorobutadiene	ND	Hexachlorocyclopentadiene	ND	Hexachloroethane	ND	Isophorone	ND	Naphthalene	ND	Nitrobenzene	ND	N-Nitroso-di-n-propylamine	ND	N-Nitrosodiphenylamine	ND	Pentachlorophenol	ND	Phenanthrene	ND	Phenols	43.8	Pyrene	ND

(1) All samples were 24 hour composites.

(3) All results in µg/L.

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Semi-volatiles
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC SEMI-VOLATILE RESULTS																																																																																																	
7/16/2013 6:00:00 PM	EPA 625	Effluent	1,2,4-Trichlorobenzene	ND	1,2-Dichlorobenzene	ND	1,2-Diphenylhydrazine	ND	1,4-Dichlorobenzene (625)	ND	2,4,6-Trichlorophenol	ND	2,4-Dichlorophenol	ND	2,4-Dimethylphenol	ND	2,4-Dinitrophenol	ND	2,4-Dinitrotoluene	ND	2,6-Dinitrotoluene	ND	2-Chloronaphthalene	ND	2-Chlorophenol	ND	2-Nitrophenol	ND	3,3'-Dichlorobenzidine	ND	4,6-dinitro-2-methylphenol	ND	4-Chloro-3-methylphenol	ND	4-Chlorophenyl-phenylether	ND	4-Nitrophenol	ND	Acenaphthene	ND	Acenaphthylene	ND	Anthracene	ND	Benzidine	ND	Benzo (a) Anthracene	ND	Benzo (a) pyrene	ND	bis (2-Chloroethoxy) methane	ND	bis (2-Chloroethyl) ether	ND	bis (2-Chloroisopropyl) ether	ND	bis (2-Ethylhexyl) phthalate	ND	Butylbenzylphthalate	ND	Chrysene	ND	Diethylphthalate	ND	Dimethylphthalate	ND	Di-n-butylphthalate	ND	Di-n-octylphthalate	ND	Fluorene	ND	Fluoranthene	ND	Hexachlorobenzene	ND	Hexachlorobutadiene	ND	Hexachlorocyclopentadiene	ND	Hexachloroethane	ND	Isophorone	ND	Naphthalene	ND	Nitrobenzene	ND	N-Nitroso-di-n-propylamine	ND	N-Nitrosodiphenylamine	ND	Pentachlorophenol	ND	Phenanthrene	ND	Phenols	0.86	Pyrene	ND

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC SEMI-VOLATILE RESULTS																																																																																																	
1/15/2014 7:45:00 AM	EPA 625	Effluent	1,2,4-Trichlorobenzene	ND	1,2-Dichlorobenzene	ND	1,2-Diphenylhydrazine	ND	1,4-Dichlorobenzene (625)	ND	2,4,6-Trichlorophenol	ND	2,4-Dichlorophenol	ND	2,4-Dimethylphenol	ND	2,4-Dinitrophenol	ND	2,4-Dinitrotoluene	ND	2,6-Dinitrotoluene	ND	2-Chloronaphthalene	ND	2-Chlorophenol	ND	2-Nitrophenol	ND	3,3'-Dichlorobenzidine	ND	4,6-dinitro-2-methylphenol	ND	4-Chloro-3-methylphenol	ND	4-Chlorophenyl-phenylether	ND	4-Nitrophenol	ND	Acenaphthene	ND	Acenaphthylene	ND	Anthracene	ND	Benzidine	ND	Benzo (a) Anthracene	ND	Benzo (a) pyrene	ND	bis (2-Chloroethoxy) methane	ND	bis (2-Chloroethyl) ether	ND	bis (2-Chloroisopropyl) ether	ND	bis (2-Ethylhexyl) phthalate	ND	Butylbenzylphthalate	ND	Chrysene	ND	Diethylphthalate	ND	Dimethylphthalate	ND	Di-n-butylphthalate	ND	Di-n-octylphthalate	ND	Fluorene	ND	Fluoranthene	ND	Hexachlorobenzene	ND	Hexachlorobutadiene	ND	Hexachlorocyclopentadiene	ND	Hexachloroethane	ND	Isophorone	ND	Naphthalene	ND	Nitrobenzene	ND	N-Nitroso-di-n-propylamine	ND	N-Nitrosodiphenylamine	ND	Pentachlorophenol	ND	Phenanthrene	ND	Phenols	0.58	Pyrene	ND

(1) All samples were 24 hour composites.

(3) All results in µg/L

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Influent and Effluent Priority Pollutant Scan: July 01, 2013 - June 30, 2014
Priority Pollutant Organic Pesticides
NPDES Permit Number: NM0022250

DATE/TIME	METHOD	SAMPLE POINT	ORGANIC PESTICIDE RESULTS							
7/16/2013 6:00:00 AM	EPA 608	Influent	4,4'-DDD	ND	4,4'-DDE	ND	4,4'-DDT	ND	Aldrin	ND
			alpha-BHC	ND	beta-BHC	ND	delta-BHC	ND	Dieldrin	ND
			Endosulfan Sulfate	ND	Endosulfan I	ND	Endosulfan II	ND	Endrin	ND
			Endrin Aldehyde	ND	gamma-BHC (Lindane)	ND	Heptachlor	ND	Heptachlor Epoxide	ND
			PCB-1016	ND	PCB-1221	ND	PCB-1232	ND	PCB-1242	ND
			PCB-1248	ND	PCB-1254	ND	PCB-1260	ND	Toxaphene	ND
1/15/2014 7:15:00 AM	EPA 608	Influent	4,4'-DDD	ND	4,4'-DDE	ND	4,4'-DDT	ND	Aldrin	ND
			alpha-BHC	ND	beta-BHC	ND	delta-BHC	ND	Dieldrin	ND
			Endosulfan Sulfate	ND	Endosulfan I	ND	Endosulfan II	ND	Endrin	ND
			Endrin Aldehyde	ND	gamma-BHC (Lindane)	ND	Heptachlor	ND	Heptachlor Epoxide	0.029
			PCB-1016	ND	PCB-1221	ND	PCB-1232	ND	PCB-1242	ND
			PCB-1248	ND	PCB-1254	ND	PCB-1260	ND	Toxaphene	ND
7/16/2013 6:00:00 PM	EPA 608	Effluent	4,4'-DDD	ND	4,4'-DDE	ND	4,4'-DDT	ND	Aldrin	ND
			alpha-BHC	ND	beta-BHC	ND	delta-BHC	ND	Dieldrin	ND
			Endosulfan Sulfate	ND	Endosulfan I	ND	Endosulfan II	ND	Endrin	ND
			Endrin Aldehyde	ND	gamma-BHC (Lindane)	ND	Heptachlor	ND	Heptachlor Epoxide	ND
			PCB-1016	ND	PCB-1221	ND	PCB-1232	ND	PCB-1242	ND
			PCB-1248	ND	PCB-1254	ND	PCB-1260	ND	Toxaphene	ND
1/15/2014 7:45:00 AM	EPA 608	Effluent	4,4'-DDD	ND	4,4'-DDE	ND	4,4'-DDT	ND	Aldrin	ND
			alpha-BHC	ND	beta-BHC	ND	delta-BHC	ND	Dieldrin	ND
			Endosulfan Sulfate	ND	Endosulfan I	ND	Endosulfan II	ND	Endrin	ND
			Endrin Aldehyde	ND	gamma-BHC (Lindane)	ND	Heptachlor	ND	Heptachlor Epoxide	ND
			PCB-1016	ND	PCB-1221	ND	PCB-1232	ND	PCB-1242	ND
			PCB-1248	ND	PCB-1254	ND	PCB-1260	ND	Toxaphene	ND

(1) All samples were 24 hour composites.

(2) Plant flow-through detention time of 12 hours, observed for all influent and effluent samples.

(3) All results in µg/L.

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

System Manholes: July 01, 2013 - June 30, 2014
Priority Pollutant Domestic Metals
NPDES Permit Number: NM0022250

SAMPLE POINT	DOMESTIC METAL RESULTS											
F11117	AG (mg/L)	<0.0016	AL (mg/L)	0.5570	AS (mg/L)	<0.0199	B (mg/L)	0.4533	CD (mg/L)	<0.0007	CR (mg/L)	<0.1300
	CU (mg/L)	0.0701	F (mg/L)	0.6115	HG (mg/L)	0.0001	MO (mg/L)	<0.0051	NI (mg/L)	<0.0029	PB (mg/L)	<0.0020
	PHENOLIC (mg/L)	<0.0884	SE (mg/L)	<0.0148	ZN (mg/L)	0.3756						
G18122	AG (mg/L)	<0.0012	AL (mg/L)	0.3609	AS (mg/L)	0.0117	B (mg/L)	0.3035	CD (mg/L)	<0.0002	CR (mg/L)	<0.0352
	CU (mg/L)	0.0752	F (mg/L)	0.4090	HG (mg/L)	<0.0000	MO (mg/L)	<0.0070	NI (mg/L)	<0.0025	PB (mg/L)	0.0024
	PHENOLIC (mg/L)	<0.0653	SE (mg/L)	<0.0017	ZN (mg/L)	0.3259						
H22282	AG (mg/L)	<0.0012	AL (mg/L)	0.4051	AS (mg/L)	0.0088	B (mg/L)	0.4196	CD (mg/L)	<0.0004	CR (mg/L)	<0.0341
	CU (mg/L)	0.0550	F (mg/L)	0.5604	HG (mg/L)	<0.0000	MO (mg/L)	<0.0049	NI (mg/L)	<0.0021	PB (mg/L)	0.0016
	PHENOLIC (mg/L)	<0.0593	SE (mg/L)	<0.0016	ZN (mg/L)	0.3746						
K23703	AG (mg/L)	<0.0010	AL (mg/L)	0.3156	AS (mg/L)	0.0097	B (mg/L)	0.2936	CD (mg/L)	<0.0003	CR (mg/L)	<0.0337
	CU (mg/L)	0.0432	F (mg/L)	0.5948	HG (mg/L)	<0.0001	MO (mg/L)	<0.0049	NI (mg/L)	<0.0021	PB (mg/L)	0.0019
	PHENOLIC (mg/L)	<0.0761	SE (mg/L)	<0.0016	ZN (mg/L)	0.3143						

- (1) All sewer system manhole locations were sampled an average of eight days via 24 Hr. time-weighted composites. Averages are shown.
 (2) Manhole Locations: Primary Domestic/Commercial Locations:
 (3) "<" appearing next to an averaged result indicates that one or more results used in the average was below detectable limit.

F11117 Domestic Manhole on Azuelo Ave. NW, East of Cordoniz
 G18122 Domestic Manhole on Maderia Dr. NE
 H22282 Domestic Manhole on Lexington NE, between Nakomis and Marie Park
 K23703 Domestic Manhole on Paseo Del Mar NE at Paseo Vista

**Albuquerque Bernalillo County Water Utility Authority
Southside Water Reclamation Plant**

Sludge/Biosolids Priority Pollutant Scan: July 01, 2013 - June 30, 2014

Priority Pollutant Metals and Cyanide

NPDES Permit Number: NM0022250

Parameter	Units	Sample Set	Sample Maximum	Sample Minimum	Sample Average
AS	mg/kg	7	19	10	<13.4
CD	mg/kg	7	1.4	0.82	1.1
CN	mg/kg	7	4.19	0.991	<1.8
CR	mg/kg	7	58	42	51.9
CU	mg/kg	7	550	460	484.3
F	mg/kg	7	120	17.2	49.7
HG	mg/kg	7	1.2	0.46	0.8
MO	mg/kg	7	26	19	22.4
NI	mg/kg	7	32	24	26.0
PB	mg/kg	7	38	25	32.0
SE	mg/kg	7	14	10	<11.9
ZN	mg/kg	7	1000	730	810.0

"<" appearing next to an averaged result indicates that one or more results used in the average was below detectable limit.

NOTE: All sludge samples are taken on a dry weight basis, post-digestion and post dewatering.

U.S. Postal Service™ Signature Confirmation® Receipt

SIGNATURE CONFIRMATION NUMBER:
99EE 029E 0000 044D 9DEE2

Gladys Gooden-Jackson
USEPA REGION 6
1445 Ross Avenue
Suite 1200
Mail Code: 6EN
Dallas, TX 75201-2733

is paid before mailing.

20140903
NPDES PRET
2013-2014 ANNUAL

POSTAL CUSTOMER: PPT
Keep this receipt. For Inquiries:
Access internet web site at
www.usps.com[®]
or call 1-800-222-1811



- Priority Mail™ Service
 First-Class Mail® parcel
 Package Services parcel

English

Customer Service

USPS Mobile

Register / Sign In



Search USPS.com or Track Packages

Quick Tools

Ship a Package

Send Mail

Manage Your Mail

Shop

Business Solutions

USPS Tracking™



Customer Service ›
Have questions? We're here to help.

Tracking Number: 23080440000036203366

Updated Delivery Day: Monday, September 8, 2014
Signed for By: T DUNNAGAN // DALLAS, TX 75202 // 11:03 am

Product & Tracking Information

Postal Product:
Priority Mail 2-Day™

Features:
\$50 Insurance included

Signature Confirmation™

Proof of Delivery

Text Updates

Email Updates

DATE & TIME	STATUS OF ITEM	LOCATION
-------------	----------------	----------

September 8, 2014 , 11:03 am	Delivered	DALLAS, TX 75202
------------------------------	-----------	------------------

Your item was delivered at 11:03 am on September 8, 2014 in DALLAS, TX 75202 to EPA. The item was signed for by T DUNNAGAN.

September 8, 2014 , 10:40 am	Out for Delivery	DALLAS, TX 75201
September 8, 2014 , 10:30 am	Sorting Complete	DALLAS, TX 75201
September 6, 2014 , 7:30 am	Arrived at Post Office	DALLAS, TX 75201
September 6, 2014 , 5:49 am	Departed USPS Facility	DALLAS, TX 75260
September 6, 2014 , 4:09 am	Arrived at USPS Facility	DALLAS, TX 75260
September 4, 2014 , 9:25 pm	Departed USPS Facility	ALBUQUERQUE, NM 87121
September 4, 2014 , 9:08 pm	Arrived at USPS Facility	ALBUQUERQUE, NM 87121
September 4, 2014 , 5:06 pm	Departed Post Office	ALBUQUERQUE, NM 87106
September 4, 2014 , 3:57 pm	Acceptance	ALBUQUERQUE, NM 87106

Track Another Package

Tracking (or receipt) number

Track It



Date: September 8, 2014

Dolores Apodaca:

The following is in response to your September 8, 2014 request for delivery information on your Signature Confirmation™ item number 23080440000036203366. The delivery record shows that this item was delivered on September 8, 2014 at 11:03 am in DALLAS, TX 75202 to T DUNNAGAN. There is no delivery signature on file for this item.

Thank you for selecting the Postal Service for your mailing needs. If you require additional assistance, please contact your local Post Office or postal representative.

Sincerely,
United States Postal Service